

1. REFER TO THE LATEST EDITION OF NFPA 20 FOR ADDITIONAL REQUIREMENTS.

- ## PIPING BY OTHERS



1 LOCKABLE FUEL CAP COMBINED WITH A REMOVABLE

- NOTES:**

- NOTES:
1. MAXIMUM ALLOWABLE FUEL HEIGHT ABOVE FUEL PUMP IS 9.8 FEET [3 METERS].
 2. CHECK VALVE OPENING PRESSURE IS 5 PSI [34.3 KPA].

[illegible]